

SECTION 6

6.22 METER CHECK VALVES:

Check valves will be required for all meters 1-1/2 inch and larger unless otherwise specified by Denver Water, whether installed in an inside or outside setting. Check valves may be required on meters smaller than 1-1/2 inch where any condition might exist that could cause a flow of water from the property to the main. Also see 6.09.